

Tank Storage Status

Version Date:

4/17/2019 7:26

Table 1: Response Tanks Storing Collected Response Liquids

Tank #	Material Stored	Tank Max Capacity (bbls)	Current Level - Total (bbls)	Water Level (bbls)	Organic Total (bbls)	Comment/Activity
80-18	Firefighting Water/Organics	71,508	69,075	25,121	43,954	No Activity
80-33	Firefighting Water/Organics	72,528	51,754	19,625	32,129	Active via Vacuum Trucks
100-28	Firefighting Water/Organics	100,297	89,666	49,447	40,219	Active via Vacuum Trucks
100-31	Firefighting Water/Organics	100,255	99,923	90,401	9,522	No Activity
100-15	Firefighting Water/Organics	100,256	11,253	1,432	9,821	Receiving Tank Farm
100-1	Firefighting Water/Organics	100,074	96,342	86,433	9,909	No Activity
		544,918	418,013	272,459	145,554	
	Available Storage	126,905				

Table 2: ITC Wastewater System Tanks

Tank #	Material Stored	Tank Max Capacity (bbls)	Current Level - Total (bbls)	Water Level (bbls)	Organic Total (bbls)	Comment/Activity
50-2	Prior Wastewater/Firefighting Water/Organics	52,084	50,878	50,688	190	
80-34	Prior Wastewater/Firefighting Water/Organics	80,287	62,216	56,629	5,587	
60-1	Prior Wastewater/Firefighting Water/Organics	54,384	50,631	44,272	6,359	
		186,755	163,725	151,589	12,136	

Table 3: Temporary Storage Vessels Loaded

Barge	Prior Wastewater/Firefighting Water/Organics	57,000	49,157	49,157		
-------	--	--------	--------	--------	--	--

Table 2: Impacted Tank Farm Information

Tank #	Material Stored Prior to Event	Safe Operating Capacity (bbls)	Current Level - Total (bbls)	Quantity Prior To Event (bbls)	Comment/Activity	Physical Status Of The Tank
80-1	Base Oil	72,978	0	49,760	COMPLETE - No Further Action Required	Tank erect, charred, damage to roof
80-2	Gas Blendstock	74,189	0	42,260	COMPLETE - No Further Action Required	Collapsed
80-3	Gas Blendstock	69,679	0	33,410	COMPLETE - No Further Action Required	Tank erect, charred, but heavily damaged
80-4	Base Oil	74,497	0	35,699	COMPLETE - No Further Action Required	Tank erect, charred, damage to roof
80-5	Xylene	72,859	Sludge	38,426	COMPLETE - No Further Action Required	Collapsed
80-6	Gas Blendstock	74,789	0	49,414	COMPLETE - No Further Action Required	Collapsed
80-7	Pygas	75,373	Sludge	43,595	Cleaning In Progress; Degassing	Half of the tank standing, roof collapsed
80-8	Naphtha	73,960	100	70,761	Product Removal Complete; Ready for Cleaning	Collapsed
80-9	EMPTY	76,521	0	Empty	COMPLETE - No Further Action Required	Collapsed
80-10	Pygas	74,767	Sludge	14,382	Cleaning In Progress; Degassing	Erect, fixed roof in tact
80-11	Base Oil	76,208	800	52,902	Product Removal Complete; Ready for Cleaning	Erect, charred, and damage to roof
80-12	EMPTY	76,502	0	Empty	COMPLETE - No Further Action Required	Partially Collapsed
80-13	Toluene	70,523	0	14,725	COMPLETE - No Further Action Required	Erect, fixed roof in tact
80-14	Pygas	72,965	Sludge	15,840	Cleaning In Progress; Degassing	Collapsed
80-15	Pygas	74,692	Sludge	9,421	COMPLETE - No Further Action Required	Collapsed
		1,110,502	900	470,595		

	Full of Product / No action
	Heel / Residual Remaining - In Process
	Cleaning or Degas
	COMPLETE - No Further Action Required